



## ***Purchasing Division***

**INVITATION TO BID:** Union Station Offices Remodel

**ADDENDUM NO.** 3

**DATE:** January 17, 2023

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made part of the bid document.

---

### **Electrical Info:**

A contractor requested that his electrical sub be allowed to visit the space and view the electrical panels that would be used for this project.

The following is the result of this visit -

1<sup>st</sup> floor office space: An electrical panel was identified in the basement within approximately 30 feet of the new wall to be built with 2 circuits available to run conduit from the panel about 50ft to the new wall location above. Contractor determined that drilling down through the floor would access the basement and conduit run to accommodate pulling the new 20 amp circuits into the new divider wall.

2<sup>nd</sup> floor office space: An electrical panel was identified on the 2<sup>nd</sup> floor within approximately 30 feet of the new wall to be built with 1 circuit available to run conduit from the panel about 50ft to the new wall location. Contractor determined that this could be accomplished through the accessible attic above, and back down into the new wall below to accommodate pulling a new 20 amp circuit into the new divider wall.

### **Acknowledgement:**

---

Name & Title

---

Firm Name

---

Authorized Signature & Date