



**Ogden City Corporation
Request for Proposal**

Parking Hardware and Software System

Q & A

For the fixed LPR cameras in the parking garages that are being built. Will there be existing CAT6 cabling to the location where the cameras will be installed? If not, is it ok for them to run CAT6 cabling neatly packaged to the IDF closet to gain power to the cameras? And approximately how many feet would it be from the camera locations to the power closet?

The city will supply three 1-inch conduits through which a CAT 6 can be run, others (separate contractor) to install and provide the CAT 6 wire. The LPR Camera G-L1.10 is 50 feet from the MDF and G-L1.11 camera is about 100 feet from the MDF room.