



Ogden City Corporation

Invitation to Bid

Community Services Building Ballistic Upgrade & Remodel

Q & A

1. The door schedule calls door type D2 as wood doors. On the Door Types on sheet AE601, it says door type D2 are to be ballistic steel. Please advise.

Doors to be Armotex level 3 wood veneered doors (or Equal). Refer to Addendum 3.

2. There is a mechanical key notes #7 in the drawings but nothing in the key notes sections. Please advise.

The key note should be no. 6. Refer to Addendum 3.

3. AE101 detail #2 – the breakdown shows LVT for the floors but it is not specified anywhere on the specs regarding manufacture, or product specs like wear layers, size, install application.

Refer to addendum 2 for the added specification.

4. AE102 detail #5 – the breakroom shows a tile backsplash but it is not specified anywhere on specs regarding manufacture or information regarding size.

The tile backsplash has been deleted. Refer to Addendum 2.

5. The flooring finish schedule list a few of the spaces 107-118 as having the same callout CP1 as the spaces that are getting new flooring. Can you help verify if the existing offices that do not have information under the room titles will have new flooring or not?

All existing carpet is to be replaced. Refer to Addendum 2. Also see added specifications in Addendum 3.